



October 15, 2007

LAKE SHORE BURIAL VAULT CO., INC.
HUBERT MCQUESTION
12780 LISBON ROAD
BROOKFIELD WI 53005

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: LAKE SHORE BURIAL VAULT CO., INC.
Product Name: AFTER TANK DCOMM APPROVED FILTER ASSEMBLY
Model Number(s): NONE
Product File No: 20070456

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2011.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- A permanent warning label that conforms to s. Comm 84.25 (8), Wis. Adm. Code, must be attached to the cover of this product.
- The manhole cover shall be provided with a locking device that conforms to s. Comm 84.25 (7)(h) of the Wisconsin Administrative Code.
- The riser joints and tank cover must be sealed with Conseal CS 301 or 302 or Press Seal CPS or equal joint sealant.

This approval supersedes the approval issued on 10/9/2006 approved plans and/or specifications approved under product file 20060389

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST; Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658; 201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov